

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7165-0075:161 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653  
Contact: Lawrence Flood (203) 484-1200

DESIGN: Models MS-4424, MS-4424B and MRP-4424 fire alarm control unit. Inherently power-limited, automatic, manual, non-coded; local, auxiliary and remote station (protected premises); proprietary (protected premises, central station (protected premises); waterflow and sprinkler supervisory (local only) service. Model MS-4424 and MS-4424B are conventional type and Model MRP-4424 is agent release type. Refer to listee's data sheet for additional detailed product description and operational considerations.

4X-TMF	Transmitter Module
4X-LMF	Interface Module
4X-ZMF	Relay Module
RZA-4XF	Remote Annunciator
4XMMF	Voltage/Current Meters

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal.

Proprietary protected premises unit: the system shall be interconnected with Potter Model EFT-C electrically actuated transmitter (CSFM Listing No. 7330-0328:104).

Central station protected premises unit: the system shall be connected to either of the following transmitters: Firelite Model NOTI-FIRE 911/911A series with ADEMCO Model 685 (CSFM Listing No. 7165-0078:133) or MS-5012 (CSFM Listing No. 7165-0075:154) control unit, or separately listed compatible control unit.

NOTE: Combined 7165-0075:115 into 7165-0075:161

XLF: 7165-0028:161 06-07-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager